SIEMENS

Data sheet BVP:203163

BD2-AK3X/GSTZ00 tap-off unit 125 A / 1x 3-pole switch disconnector




Figure similar

Model	
product designation	tap-off unit for BD2 busbar trunking system
operating voltage at AC	
● at 50 Hz rated value maximum	690 V
● at 60 Hz rated value maximum	690 V
Protection class	
protection class IP	IP54, mit Zusatzausruestung: IP55
Main circuit	
operating frequency rated value	
● minimum	50 Hz
● maximum	60 Hz
operational current	
● for circuit 1 at AC at 50 Hz rated value maximum	125 A
● for circuit 1 at AC at 60 Hz rated value maximum	125 A
Connections	
connectable conductor cross-section in the outgoing unit	
● minimum	10 mm²
Tap-off points	
outgoing unit version	cable entry
design of short-circuit and overloading protection in the outgoing unit	3-pole NH00 125 A fuse switch-disconnector
size of the outgoing unit	3
number of poles of the outgoing unit	5
Mechanical Design	
height	215 mm
width	205 mm
length	440 mm
product component locking mechanism	Yes
Net Weight	6.96 kg
Approvals Certificates	
General Product Approval	

CE
EG-Konf.

Further information

Subject to change without notice
© Copyright Siemens

Information on the packaging
https://support.industry.siemens.com/cs/ww/en/view/109813875
Information for data generation and storage
https://support.industry.siemens.com/cs/ww/en/view/109995012
Information- and Downloadcenter (Catalogs, Brochures,…)
https://www.siemens.com/lowvoltage/catalogs
Industry Mall (Online ordering system)
https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=BVP:203163
Service&Support (Manuals, Certificates, Characteristics, FAQs,...)
https://support.industry.siemens.com/cs/ww/en/ps/BVP:203163
Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)
https://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=BVP:203163
CAx-Online-Generator
https://www.siemens.com/cax
Tender specifications
https://www.siemens.com/specifications
Kennlinien
https://curves.simaris.siemens.com/curves/BVP:203163

last modified: 9/2/2024

Subject to change without notice
© Copyright Siemens

Subject to change without notice
© Copyright Siemens