Ref. Certif. No.

SE-118220

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Uninterruptable power supply
Name and address of the applicant	Bicker Elektronik GmbH Ludwig-Auer-Straße 23 86609 Donauwörth GERMANY
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: *When more than one factory, please report on page 2*	Same as applicant ☐ Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	-
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	UPSI-2415DP2xxxxxxx, UPSI-2415DP3xxxxxxx, UPSI-2410DP2xxxxxxx, UPSI-2410DP3xxxxxxx
Additional information (if necessary may also be reported on page 2)	☒ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010 + A1 IEC 61010-2-201:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	2256564KAU-001A, 2256564KAU-001B

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 8 January, 2026

intertek

Signature:

Ratings and principal characteristics

UPSI-2415 models:
Input: 24 VDC, 17.5 A
Output (normal mode): 24 VDC, 15 A
Output (backup mode): 24.5 VDC, 15 A
UPSI-2410 models:
Input: 24 VDC, 13 A
Output (normal mode): 24 VDC, 10 A
Output (backup mode): 24.5 VDC, 10 A

Additional information

Explanation of models:
The undefined seven characters show differences in software and/or other features that are not relevant to safety.

The National Differences of USA and Canada were checked.

Date: 8 January, 2026

Signature: